

September 19, 2018

**ADDENDUM NO. 1**

**Filter Media Replacement**

Notice is hereby given that the following additional information and changes shall become part of the specifications of the above referenced contract. You are to acknowledge the addenda on the Proposal Sheet.

1. Page P 2 of 13, Item 1 to read as follows:

Lump sum for multi-media filter replacement.

2. Page S 3 of 3, E. to read as follows:

E. Contract item (Pay Item)

Filter Media Replacement.....\$Lump Sum

Inspection.....\$Lump Sum

Replacement Parts and Labor (as required, a change order will be issued)

3. Special Provisions page 2 of 2, C, 3. Coating Application Schedule to read as follows:

3. Coating Application Schedule

Four (4) Multi-Media Removal Filters

A. Exterior Ferrous Metal: All exterior surfaces above grade.

B. Submerged or Intermittently Submerged Ferrous Metal: All interior surfaces above the underdrain.

4. Support Gravel Specifications:

Support gravel specifications shall include the following information:

1. The measurements for the support gravel should be in inches. That is the industry standard.
2. The media should be in accordance with AWWA B-100 standards.
3. Garnet sand should be 3.8 specific gravity or higher.
4. Silica sand should be 2.5 SG or higher

5. Third Party Inspections:

The City of Jackson has contracted with Dixon Engineering to perform third party inspections of the media filter replacement contract.

END OF ADDENDUM