



NOTES:

1. CONTRACTION JOINTS TO BE PLACED AT INTERVALS NOT EXCEEDING SIX (6') FEET NOR LESS THAN FOUR (4') FEET. ALL CONTRACTION JOINTS SHALL BE CUT TO A DEPTH OF NOT LESS THAN ONE-FOURTH ( $\frac{1}{4}$ ) THE DEPTH OF THE SIDEWALK.
2. PLACE ONE-HALF ( $\frac{1}{2}$ ") INCH EXPANSION JOINT WHERE WALK MEETS CURB, CROSSWALKS, AND AT INTERVALS NOT EXCEEDING FIFTY (50') FEET OR AS DIRECTED BY ENGINEER.

## STD. SIDEWALK DETAIL

N.T.S.